

## AM-BSA-N Series

### Water Wash Low Proximity Exhaust Ventilator

AquaMatic's ETL Listed AM-BSA-N is a low proximity exhaust ventilator with an automatic internal water wash system.

The AM-BSA-N is a Type 1, wall mounted exhaust canopy utilizing high velocity slot type grease extraction with an automatic internal water wash system, and integrated wash and rinse cycles.

---

#### FEATURES

- ETL Listed and NSF Listed Product
- Automatic Internal Water Wash System
- Choice of Electromechanical or Solid State Programmable Control Panels
- Superior Exhaust Flow Rates
- Exceptional Capture and Containment of Cooking Vapors
- Wall Configuration
- 100% Type 304 Stainless Steel Construction
- Front Exposed Corners Ground and Polished to Match Grain of Ventilator
- Grease Extracting Cartridges
- Grease Drain System
- Removable Access Doors for Exhaust Plenum Access
- Pre-punched Hanging Angles
- Integral Stainless Steel Double End Panels

---

#### CONTROL PANEL OPTIONS

AM-2 Control Panel provides push button operation with relay control of the exhaust and make-up air fans as well as the cleaning cycle of the ventilator. The time period of the rinse cycle is adjustable up to 3 minutes. The control panel includes a combination pressure/temperature gauge, shock absorber, pressure reducing valve, water solenoid valve, detergent pump, line strainer, and gate valve. See product specification sheet for details.

TAC-3000 Control Panel is a state-of-the-art, 24 hour, seven day, solid state water wash control panel. Featured is its' four line liquid crystal display and user-friendly menu driven programming. Door mounted indicator lights show the status of supply and exhaust fans, fire condition, water valve, and AC power. Buttons on the stainless steel door are used to control the programming and are touch sensitive with no moving parts. It is capable of controlling up to 5 wash zones independently with user selected durations and delay time between washings as well as controlling the fan ON and OFF times.

---

#### OPTIONS

- Fire Suppression System
- Back Supply Air Plenum
- Dry Slot with No Internal Wash System
- Cold Water Mist
- ETL Listed Exhaust Fire Damper
- Enclosure Panels to Ceiling
- Roof Top Packages
- Exhaust Fans
- Make-Up Air Units:
  - Untempared Units
  - Direct Gas Fired Heated Units
  - Indirect Gas Fired Heated Units
  - Electric Heated Units
  - Heating & Cooling Coils

---

## AQUAMATIC'S INTEGRATED SYSTEM

---

AquaMatic® offers a total system to insure maximum installation and operating efficiencies. Components consist of the ventilator, fire system and electrical controls contained within an integral utility cabinet, and fan packages including exhaust, untempered and tempered make-up air packages. Also available are air purification and energy management systems. Fire suppression systems include final hookup and inspection. Call your AquaMatic Representative for more details.

---

## PERFORMANCE DATA

---

Max. Avg. Cooking Surface Temp. (°F)	Configuration	Min. Exhaust CFM/ft.	Recommended Duct Sizing
600°F - Ovens, Steamers, Kettles, Open-Burner Ranges, Griddles, Fryers, Gas Charbroilers, Electric Charbroilers	Single Wall Hood	250	Exhaust Based on 1500 FPM
	2 Wall Hoods Back-to-Back in an Island Configuration	500	Supply Based on 800 FPM

---

## SPECIFICATIONS

---

### Application

The ventilator shall provide flexibility in designing kitchen ventilation equipment and shall be tested and listed for use over light, medium and heavy duty cooking surfaces, maximum 600°F.

### Construction

The ventilator shall be 100% constructed of Type 304 stainless steel with #3 or #4 polish. All seams shall be welded or in conformance with ETL standards. Front exposed corners shall be ground and polished to match the ventilator grain. Individual component construction shall be determined by manufacturer, ETL and NSF. Construction shall be dependent on the structural application to minimize distortion and other defects. All seams, joints and penetrations of the ventilator where grease-laden vapors and exhaust gases are present, must be liquid-tight, continuous welds in accordance with NFPA 96.

### The ventilator shall be constructed to include:

- [A full length, horizontal exhaust inlet slot](#) and a series of fixed baffles for grease removal.
- [An integral drain system](#) on the ventilator back. Multiple end-to-end ventilators can be manifolded to one common drain.
- [Exhaust duct collar 5" high with 1" flange.](#)
- [A minimum of four connections](#) for hanger rods. Connectors shall have 9/16" holes pre-punched in 1 1/2" x 1 1/2" angle iron at the factory to allow for hanger rod connection by others.
- [Heavy duty, removable grease extracting cartridge](#), with size and quantity determined by the hood's dimensional parameters, not to exceed 60" in length.

### Certifications

The ventilator shall be ETL Listed as "Exhaust Hoods Without Exhaust Damper", ETL Listed to Canadian Safety Standards, NSF Listed and built in accordance with NFPA 96.

### Documentation

Manufacturer shall furnish complete computer generated submittal drawings including ventilator section view(s), plan view(s), duct sizing, and CFM and static pressure requirements. Static pressure, air velocity and air volume requirements indicated on drawings shall be precise and accurate and ventilator shall preform to said specifications. Drawings shall be available to the engineer, architect and owner for their use in construction, operation and maintenance.

---

## ADDITIONAL INFORMATION


---

- [Hood System Curves](#)
- [Operation & Maintenance Manual](#)
- [Request Product Information](#)
- [Schlieren Testing Videos](#)

---

## SECTIONAL VIEWS

---



SECTION VIEW MODEL BSA

### CERTIFICATIONS

The AM-BSA-N Model has been certified by ITS. This certification mark indicates that the product has been tested to and has met the minimum requirements of a widely recognized (consensus) U.S. and Canadian products safety standard, that the manufacturing site has been audited, and that the applicant has agreed to a program of periodic factory follow-up inspections to verify continued performance.



Models AM-BSA-N are ETL Listed under file number 3054804-001 and complies with UL710 Standards and ULC710 Standards.